



### SCHEMATIC

NOTE: BACKFLOW PREVENTER DRIPS SO FLOOR DRAIN TO STORM DRAIN IS REQUIRED.

FOR REFERENCE ONLY

**JCC**  
**CODE COMPLIANCE**

REQUIREMENTS FOR  
DETECTOR CHECK IN  
MECHANICAL ROOM

DWG NO. C1.1

SCALE: NTS

DWN BY: DW

DATE: 1-08-07

REVISION	DATE	COMMENT
9/18/07		REVISED NOTE & DWG NO.